

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtltt1@gmail.com



TC-14756

TEST REPORT

Name & Address of Customer : Doon Public School Assal , Patti , Tarn Taran		Customer Reference No.	No : 966 Dated : 21/05/2026
		Sample Submitted by	Mr. Amarpreet Singh
		Date of Sample Receipt	21/05/2026
		Analysis Starting Date	21/05/2026
		Analysis completion Date	22/05/2026
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC147562600000182F	Sample Type :	Treated Water
Test Report No.:	DWTLTT/2627/00091	Date of Issue :	22/05/2026
Registration no.:	DWTLTT/REG2627/00183	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Aassal	Habitation :	Aassal
Block:	Patti	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	8.27@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	152@180°C	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.51@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO ₃)	120	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO ₃)	72	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	9.62	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	11.66	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	19.99	250	1000	mg/l.	IS 3025 (Part 32-2025) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For,District Water Testing Laboratory
Tarn Taran

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtltt1@gmail.com

To,

Doon Public School
Assal , Patti , Tarn Taran


No.: DWTLTT/2627/00091 Dated : 22/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 966 Dated: 21/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 21/05/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Tarn Taran

D/A : Test Report



**Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran**

Annexure C

**PROFORMA FOR SAFE DRINKING WATER & SANITARY
CONDITIONS CERTIFICATE**

No. 475

Dated 27/05/2026

It is certified that as inspection team headed by Sh. Jasdeep Singh Sub Divisional Engineer, from Water Supply and Sanitation Sub Division Patti inspected the Doon Public School, Patti on 25.05.2026 and on the basis of Water Test Report bearing no.DWTLTT/2627/00091 dated 22.05.2026 of District Water Testing Laboratory Tarn Taran certified that the Doon Public, Patti has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the camps as per norms prescribed by the Central/State/U.T. Govt..

The Above is valid till 31.03.2027


Sub Divisional Engineer
Water Supply and Sanitation
Sub Division Patti

Signature with seal.....

Name.....Jasdeep Singh.....

Designation.....Sub Divisional Engineer.....

Name & Address of Office.....Water Supply
and Sanitation Sub Div. Patti